




Republic of the Philippines
Department of Education
REGION II – CAGAYAN VALLEY
SCHOOLS DIVISION OF BATANES
102328 – SABTANG CENTRAL SCHOOL
Sabtang, Batanes



September 23, 2024

ALFREDO B. GUMARU JR., EdD CESO V

Schools Division Superintendent
Schools Division of Batanes
Basco Batanes

Sir:

This is to inform your office that on September 21, 2024 at 3:10 PM a fire incident occurred in Sabtang Central school Faculty room due to faulty circuit breaker.

According to the interviewed teacher Mrs. Lyhna C. Aquino, Teacher 3, she has just passed by in the TEEP Building at the faculty room when there was a sudden sparked from the circuit breaker and immediately followed by a fire. She ran outside and called for help and luckily two students who passed by heard her and one of them immediately ran to the fire station which was about 60 meters away from the site to inform them. The Bureau of Fire Protection personnel responded at once and used fire extinguishers to put out the fire.


The impact of the initial assessment, are the following;

- No major infrastructure damages
- No casualties and injuries
- Temporary power outage on the whole building affecting four classrooms, faculty room and the school library
- A rough estimated damage of Ph75, 000.00 was made for
 - * panel board
 - * seven pieces circuit breaker
 - * 1 coil 2.0 wire
 - * 1 coil 3.5 wire
 - * 100 meters 5.5 wire, and
 - * labor of 2 pax @ 800/day for 3 days

It is highly recommended that a major inspection from licensed professional electrical engineers should be conducted for possible re-wiring of the whole school building.

An emergency fund is needed to augment the initial damages which include panel board, circuit breaker, wire, and others including labor. Request of fire extinguishers in every room is highly recommended.

Very truly yours,


OLIVER V. BALLESTEROS
School Principal 1



Address: Sinakan, Sabtang, Batanes
Contact No.: 09753997119
Email Address: sabtangcentralschool@deped.gov.ph
Facebook Account: Scs Sabtang